



NOTES

1. DRAWING NOT TO SCALE.
2. APPROVED BACKFLOW PREVENTER, HERSEY MODEL FDC, WATTS SERIES 007, WILKINS MODEL 950XL, FEBCO MODEL 805Y.
3. METER BOXES MUST BE CAST IRON WITH CAST IRON LIDS.
4. BALL VALVES MUST HAVE BRONZE BODIES AND S.S. HANDLES.
5. PERMITS, PLAN APPROVALS, AND INSPECTIONS MUST BE OBTAINED AND SCHEDULED PRIOR TO WORK THROUGH THE CITY OF COVINGTON ENVIRONMENTAL COMPLIANCE DEPARTMENT BY CALLING (770) 385-2085.

**CITY OF COVINGTON CROSS-CONNECTION
CONTROL PROGRAM**

**DOUBLE CHECK BACKFLOW PREVENTER SIZE 3/4"–2"
BELOW GROUND TYPICAL INSTALLATION**

STANDARD
No.
07

DEC. 1995