

Environmental Compliance Standards for Review

SHOW LOCATION OF DOMESTIC BACKFLOW DEVICE,
IRRIGATION AND FIRE VAULT

HAVE BACKFLOW DETAILS ON ALL BLUE PRINTS

1. DOMESTIC-DOUBLE CHECK
2. IRRIGATION-RPZ
3. FIRE –DOUBLE DETECTOR CHECK

ALL BACKFLOW DEVICE WILL HAVE TO BE TESTED BY A
CERTIFIED TESTER CALL FOR LIST OF TESTER

770-385-2085 OR 678-858-0154

OIL & GREASE

LOCATION OF GREASE TRAP ON ALL PLANS

GREASE TRAP DETAIL (CITY)

INDUSTRIAL PRETREATMENT

IF INDUSTRY DISCHARGES MORE THAN 25,000 GALS OF
PROCESS WATER THEY MUST FILL OUT A PERMIT APPLACTION